

PRODUCT CHANGE NOTIFICATION

#PCN-TT-RHED-15

Business Unit	Product Line Code	Type of Change	Action	Date of issue
TT	CL2	Electrical	Notify Distributors and Field	11/24/2015

The following Phoenix Contact products have been modified. Existing specifications will be met or exceeded. Please review and acknowledge this document and inform your personnel as needed.

Description of Change:

Products in this notice have had a change in approval/compliance status. These products now have the UL Listed mark per UL 497B.

Warranty Information:

N/A

Stock Status

Can existing stock still be used? Y


Is mixture of stock acceptable? N (Stock can be mixed if approval/certification is not required.)

Transaction Dates:

Date modification goes into effect from Germany: 6/12/2015

Expected first shipment (from Phoenix Contact) of the modified product(s): 7/1/2015

PRODUCT CHANGE NOTIFICATION

Previous Product	New Product
	

Should you have any issues with the timeline or content of this change, please contact Phoenix Contact using the contact information below. Customers should acknowledge receipt of the PCN within 30 days of delivery of the PCN; provided, however that the failure to acknowledge receipt does not affect the product change or the effective date thereof.

Contact Info:

Jack Coghlan
jcoghlan@phoenixcon.com
(717) 944-1300 x3531

Thank you,



Surge and Overcurrent Protection, Product Marketing Manager

Part#	Type Description
2803865	TT-EX(I)-M-24DC
2920641	TT-2-PE-M-24DC
2920722	TT-2/2-M-24DC
2920638	TT-2-PE/S1-M-24DC
2920654	TT-D-2-PE-M-BK
2803878	TT-D-2-PE-M-BU